

1 **UNITED KINGDOM CONFORMITY ASSESSMENT**
2 **UK TYPE EXAMINATION CERTIFICATE**

3 **Product Intended for use in Potentially Explosive Atmospheres**
4 **UKSI 2016:1107 (as amended by UKSI 2019:696) – Schedule 3A, Part 1**

5 Type Examination Certificate Number: **ExVeritas 23UKEX1540X** Issue: **0**

6 Equipment: **Cocoon Habitat – Pressurised Room and Control System**

7 Manufacturer: **Cairn Safety Technology**

8 Address: **3 Telford Square, Livingston, Scotland, EH54 5PQ, United Kingdom**

9 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

10 ExVeritas Limited Approved Body number 2585, in accordance with Regulation 42 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended by UKSI 2019:696), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

11 Compliance with the applicable Essential Health and Safety Requirements has been assured by compliance with:


EN IEC 60079-0: 2018 EN 60079-13:2017 EN 50381:2014

Except in respect of those requirements listed at section 16 of the schedule to this certificate.

12 If the sign “X” is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

13 This TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.

14 The marking of the equipment shall include the following:

 II 2 G Ex pb IIB/IIB + H2 T4 Gb
II 2 G EEx v2 IIB/IIB+H2 T4

T_{amb} -40°C/-20°C to +40°C/+50°C/+55°C

Gas group and ambient temperature marked is dependent upon the certified parts used in the control system.



No. 8613

On behalf of ExVeritas



S Clarke CEng MSc FIET
Managing Director

This certificate may only be reproduced in its entirety and without any change, schedule included.
The status of this certificate can be verified at www.exveritas.com
For help or assistance relating to this certificate, contact info@exveritas.com.
ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.
ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.

Schedule

13 Description of Product

The 'Cocoon Habitat' pressurised room (Habitat) and control system is designed to provide a temporary room that can reduce a Zone 1 or Zone 2 area to a safe area within the room. The room can be configured in multiple arrangements to provide rooms of different volumes and physical layout. This is achieved with prefabricated panels, airlock, air outlet, air inlet, airflow fans and safety control system.

Refer to manufacturer's maintenance schedules and procedures for further details.

14 Descriptive Documents

14.1 Associated Report and Certificate History:

Report Number	Cert Issue Date	Issue	Comment
R4257/A/1	2023-08-29	0	Initial issue of the Prime Certificate

14.2 Compliance Drawings:

Title:	Drawing No.:	Rev. Level:	Date:
Cairn Cocoon Habitat - EX GA Sheets 1 to 6	CST-DWG-0001	00	01-09-22
Cairn Cocoon Habitat User Guide	CST-UK-OPS-CM-2022	1	04-11-22
Cairn Cocoon Habitat Checklist	CST-UK-OPS-CS-2022	1	-

15 Specific Conditions of Use

15.1 Special Conditions for Safe Use

- Equipment must only be installed and operated by personnel trained on the equipment. Equipment must be installed in accordance with user instructions, habitat checklist requirements and single door procedure where applicable.
- Habitats must be constructed such that no dead air spaces are created where gases may accumulate. Inlets and outlets are to be located and arranged such that the clean air flow is evenly distributed considering the density of gases and vapours that may be present before and during operation, including internal sources of release such as acetylene.
- Hot work shall be arranged and conducted as to reduce the likelihood of generated sparks or hot particles from contacting door, duct, or penetration panels. Welding curtains/blankets/screens may be used to aid in hot particles management.
- Habitat panels and ducts for clean air supply and exhaust should be leak free and protected from mechanical damage. Parts must be inspected prior to each use.
- Equipment inside the room not rated for the external EPL must be powered via the Einstein Control System.
- The exhaust duct, and single door if used, shall be guarded from high wind speeds by use of windbreaks or other means. In addition, when a single door is used, consideration should be given when wind speeds may exceed the minimum required 0.3 m/s face velocity of the door, which may cause the infiltration of the external explosive atmosphere.
- When Venturi extraction is used, it shall be positioned away from walls of the habitat to prevent the external atmosphere being drawn in - See manual for more details.

Certificate: **ExVeritas 23UKEX1540X**

Issue **0**

This certificate may only be reproduced in its entirety and without any change, schedule included.
 For help or assistance relating to this certificate, contact info@exveritas.com.
 ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.
 ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.

Schedule

- No non-ventilated enclosures containing electrical equipment and exceeding 5% of the total habitat volume shall be present within the habitat.
- In the case of system failure, all hot parts shall immediately, and before opening of the habitat door, be quenched. Water or other appropriate means based on application to quickly cool hot surfaces is to be readily available to prevent an ignition in the event the pressurisation or ventilation system fails.
- The use of the supplied gas detector and location of the gas detector must be deemed sufficient based upon end-user process risk evaluation. Guidance can be found in IEC 60079-29.
- Discharge of the room ventilation system shall be positioned in open air and free from any constructional features which may allow for discharged gases to accumulate.
- The inlet shall be suitably located such that the air supplied to the habitat is from a non-hazardous area.
- The end user must ensure that the indicators and operators on the lid of the Ex d control box are suitably protected from the risk of external impacts when the equipment is in use.
- All certificate conditions for the individual certified parts must be met in addition to the requirements of this certificate.

15.2 Routine tests

- None

16 Essential Health and Safety Requirements (Regulations Schedule 1)

Essential Health and Safety Requirements are addressed by the standards listed in section 9 and where required the report listed in section 14.1.

The manufacturer shall inform ExVeritas of any modifications to the design of the product described by this schedule.

Certificate: **ExVeritas 23UKEX1540X**

Issue **0**

This certificate may only be reproduced in its entirety and without any change, schedule included.
For help or assistance relating to this certificate, contact info@exveritas.com.
ExVeritas, Units 16-18, Abenbury Way, Wrexham Industrial Estate, Wrexham, United Kingdom LL13 9UZ.
ExVeritas® is a registered trademark, unauthorised use will lead to prosecution.